

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT				1. CONTRACT ID CODE J		PAGE OF PAGES 1 2	
2. AMENDMENT/MODIFICATION NO. 0006		3. EFFECTIVE DATE 10-Jun-2004		4. REQUISITION/PURCHASE REQ. NO. W81G67-3097-8530		5. PROJECT NO.(If applicable)	
6. ISSUED BY CONTRACTING DIVISION USACE - ST. PAUL 190 5TH STREET E ST. PAUL MN 55101		CODE W912ES		7. ADMINISTERED BY (If other than item 6) See Item 6		CODE	
8. NAME AND ADDRESS OF CONTRACTOR (No., Street, County, State and Zip Code)				X		9A. AMENDMENT OF SOLICITATION NO. DACW37-03-B-0010	
				X		9B. DATED (SEE ITEM 11) 04-May-2004	
						10A. MOD. OF CONTRACT/ORDER NO.	
						10B. DATED (SEE ITEM 13)	
CODE		FACILITY CODE					
11. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS							
<input checked="" type="checkbox"/> The above numbered solicitation is amended as set forth in Item 14. The hour and date specified for receipt of Offer <input checked="" type="checkbox"/> is extended, <input type="checkbox"/> is not extended. Offer must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended by one of the following methods: (a) By completing Items 8 and 15, and returning _____ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment you desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.							
12. ACCOUNTING AND APPROPRIATION DATA (If required)							
13. THIS ITEM APPLIES ONLY TO MODIFICATIONS OF CONTRACTS/ORDERS. IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 14.							
A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 14 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 10A.							
B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 14, PURSUANT TO THE AUTHORITY OF FAR 43.103(B).							
C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:							
D. OTHER (Specify type of modification and authority)							
E. IMPORTANT: Contractor <input type="checkbox"/> is not, <input type="checkbox"/> is required to sign this document and return _____ copies to the issuing office.							
14. DESCRIPTION OF AMENDMENT/MODIFICATION (Organized by UCF section headings, including solicitation/contract subject matter where feasible.) The purpose of this amendment is to change portions of the specifications. The bid opening date is extended to 22 June 2004.							
Except as provided herein, all terms and conditions of the document referenced in Item 9A or 10A, as heretofore changed, remains unchanged and in full force and effect.							
15A. NAME AND TITLE OF SIGNER (Type or print)				16A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print)			
				TEL: _____ EMAIL: _____			
15B. CONTRACTOR/OFFEROR _____ (Signature of person authorized to sign)		15C. DATE SIGNED		16B. UNITED STATES OF AMERICA BY _____ (Signature of Contracting Officer)		16C. DATE SIGNED 10-Jun-2004	

SECTION SF 30 BLOCK 14 CONTINUATION PAGE

SUMMARY OF CHANGES

1. SECTION 00010 - SOLICITATION CONTRACT FORM

The required response date/time has changed from 15-Jun-2004 02:00 PM to 22-Jun-2004 02:00 PM.

2. Electrical Changes and Clarifications to Drawings.

Drawing No. M47-P-56/023, Sht. 23 of 27:

A. Coordinate E-6 – PLAN VIEW: Add telephone outlet/network protector adjacent to panel “SHP”.

B. Coordinate E-6: Change “UTILITY METER” tag to read “UTILITY METER (SEE NOTE 6).

C. Coordinate G-1: Add new note 6 as follows:

“6. COORDINATE AND PAY ALL UTILITY CO. CHARGES. ASSUME MIN 50’
UNDERGROUND SERVICE LATERAL CIRCUIT SDF.

D. Coordinate G-1: Add the following notes:

POWER COMPANY
LAKE COUNTRY POWER
2810 ELIDA DR.
GRAND RAPIDS, MN
(800) 421-9959
ATTN: JENNIFER

TELEPHONE COMPANY
Paul Bunyan Telephone Co.
(218) 751-3552

Drawing No. M47-P-56/025, Sht. 25 of 27:

A. CABLE SCHEDULE: Change Circuit PGOH, from 2-#12 to 2-#8.

B. CABLE SCHEDULE: Change Circuits RF1, & RF2 conductor sizes from 2-#12 W/1-#12 GND to 2-#8 w/1-#12 GND.

(End of Summary of Changes)